

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-0410:140 Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: Hochiki America, 7051 Village Drive, Suite 100, Buena Park, CA 90621-2268
*Contact: Bob Misiuk (714) 670-3251 Fax (714) 690-7890

DESIGN: Model ALA-EA detector with Model YBC-RL/2NC base, and Model ALB-EA with Models YBC-RL/2NC and YBF-RL/2NBE bases. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors for use with Fike Model 10-201 control unit (CSFM Listing No. 7165-0900:106).

*Rev. 11-16-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 14, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager